



ASHRAE 90.1-2019 table 9.4.5 has the following allowances for exterior lighting power:

Stairways

1.0 w/sq ft.

Walkways less than 10 ft. wide

1.0 w/linear ft.

Walkways 10 ft. wide or greater

0.2 w/sq ft.

